



CONSTRUCTION NOTES

1. PERMITS SHALL BE REQUIRED FOR ANY EXCAVATION OVER 5 FEET IN DEPTH, INTO WHICH A PERSON IS REQUIRED TO DESCEND OR ANY EXCAVATION LESS THAN 5 FEET IN DEPTH IN SOILS WHERE HAZARDOUS GROUND MOVEMENT MAY BE EXPECTED AND INTO WHICH A PERSON IS REQUIRED TO DESCEND.
2. PIPE TO BE LAID WITH LABEL UP ON EACH JOINT.
3. ROAD REPAIR SHALL CONFORM TO JURISDICTIONAL AGENCY PERMIT CONDITIONS AND SPECIFICATIONS. PRIVATE ROADS SHALL FOLLOW STANDARD SPECIFICATION 32 12 16.
4. SEWER UTILITIES ARE NOT PERMITTED WITHIN 10' HORIZONTALLY AND/OR 1' VERTICALLY OF WATER FACILITIES.
5. RECYCLED WATER AND STORM DRAIN UTILITIES ARE NOT PERMITTED WITHIN 5' HORIZONTALLY AND/OR 1' VERTICALLY OF WATER FACILITIES.

EL DORADO IRRIGATION DISTRICT

WATER TRENCH SECTION – PRIVATE

ITEM #	DESCRIPTION
1	WARNING TAPE PER W08
2	TRACER WIRE, SEE W19

DRAWN BY	SCALE NONE	REVISION	DATE	BY	EID STANDARD DRAWING NO. W10D
APPROVED	DATE				

M:\STANDARD DESIGN DETAILS CAD\10_MODEL\2021_DETAILS.DWG